


Guardian ShieldTM



Well Performance Before & After OSI's BHA Design



© 2020 Odessa Separator, Inc Office: (432)-580-7111 www.odessaseparator.com



- Average motor temperature and Fluid temperature almost dropped by 100° F. Average motor temperature dropped from 182.3° F to 139.3° F after OSI's tool installation

- The difference between motor temperature and fluid temperature is 2° F indicating high gas separation efficiency with negligible free




gas presence

- Along with that, the fluctuations in the temperature has reduced and become constant which hadn't been observed before

- Motor frequency remained stable which prevented ESP shutdowns, increasing the pump efficiency

© 2020 Odessa Separator, Inc Office: (432)-580-7111 www.odessaseparator.com







© 2020 Odessa Separator, Inc Office: (432)-580-7111 www.odessaseparator.com

